

Bellaterra : 03rd March 2020
Dossier number : **19/21100-3619**
Petitioner's reference : **TOPCRET**
Gran Via de les Corts Catalanes 828
08016 Barcelona

TEST REPORT

RECEIVED MATERIAL

On december 12th, 2019, Applus Laboratories received several applied substrates of mortar with the following reference:

MICROCEMENTO

REQUESTED TESTS:

1- Artificial ageing, UNE-EN 1062-11 Item 4.2 (500 hours)

TESTS DATE: from 11/12/2019 to 25/02/2020

RESULTS: See annexes pages

Responsible for Construction Mat.
LGAI Technological Center, S.A.

Technician Responsible
LGAI Technological Center, S.A.

The results specified in this document correspond exclusively to the material received in Applus Laboratories and tested according to the indications that they present.

The reproduction of this document is only authorised if it is made in its totality. Electronically signed reports in digital format are considered original documents, as well as its electronic copies. Their printing has no legal validity.

Report no. 19/21100-3619	Page 2
TOPCRET	MICROCEMENTO

RESULTS:

1- Artificial ageing, UNE-EN 1062-11 Item 4.2 (500 hours)

Equipment: UV ATLAS Chamber

Lamps: Type 2 (UVA 340)

Cycle: - 4 hours UV - (60±3) °C
- 4 horas humidity- (50±3) °C

*Test duration: **500 hous**

Expression of results:

Visual variation of appearance and defects according to standards EN ISO 4628-2; EN ISO 4628-4; EN ISO 4628-5

* After the test, the following results are observed:

- No blisters s/n UNE EN ISO 4628-2
- No cracks s/n UNE EN ISO 4628-4
- No scaled s/n UNE EN ISO 4628-5

No colour change variation

Garantía de Calidad de Servicio

Applus+, garantiza que este trabajo se ha realizado dentro de lo exigido por nuestro Sistema de Calidad y Sostenibilidad, habiéndose cumplido las condiciones contractuales y la normativa legal.

En el marco de nuestro programa de mejora, les agradecemos nos transmitan cualquier comentario que consideren oportuno, dirigiéndose al responsable que firma este escrito, o bien, al Director de Calidad de Applus+, en la dirección: satisfaccion.cliente@applus.com